

WWS

## CITY OF MOUNTAIN VIEW

SFUND RECORDS CTR  
2807-92000

SFUND RECORDS CTR  
**88172171**

Public Works  
(415) 966-6311

July 8, 1981

Mr. James Van Sant  
Fairchild Camera and Instrument Corporation  
Mail Stop 20-1022  
464 Ellis Street  
Mountain View, CA 94032

Dear Mr. Van Sant:

**INDUSTRIAL WASTE DISCHARGE CONTROL**

As discussed with you over the telephone last week, industrial waste violations were found through our wastewater sampling at Fairchild's Building 19 on May 8, 1981 and at Building 20 on May 11, 1981.

The analyses were made on a composite of 26 hourly samples, and the results are as follows:

<u>Location</u>	<u>Toxicant</u>	<u>Concentration Found</u>	<u>Maximum Allowable Concentration</u>
Building 19	cyanide	2.6 mg/l	1.0 mg/l
Building 20	fluoride	6.0 mg/l	5.0 mg/l

Please take corrective action immediately to assure that concentrations of the above constituents are kept below the maximum allowable concentrations shown and as set forth in Section 35.32.19 of the Mountain View City Code. In addition, please advise me in writing by July 27, 1981 of the corrective actions taken and include the results of at least two separate samples of effluent from each location listed above. These samples should be collected during periods of normal production, and these samples must be analyzed by a laboratory approved by the State Department of Health.

If you have any questions, please call me at 966-6329.

Sincerely,

Morgan H. Loegge  
Water Division Engineer

MHL/ZB-A23

CC: W. A. Chapman

S. T. Hayashi

PWD